

Product Details and Certifications

Cross Reference RA Part Number: 1492-EC85 A

 Product: **1492-EC85**

Description: 1492 Panel Mount Block, , Pull apart, 5-Pole



Representative Photo Only (actual product may vary based on configuration sections)

PANEL MOUNT BLOCK DATA

Bulletin Number	1492 Panel Block
Base Block Type	Pull-Apart Blocks
Number of Poles	5 Pole
Terminal Type	Standard

CERTIFICATIONS AND APPROVALS

UR
CSA

For UL Certifications Directory:

<http://database.ul.com/cgi-bin/XYV/template/LISEXT/1FRAME/index.htm>



Bulletin 1492
NEMA/EEMAC Terminal Blocks
 Panel Mount Blocks



1492-EC85

1492-ED103

Dimensions are not intended to be used for manufacturing purposes.



	1492-EC85		1492-ED103	
	5-pole terminal block. Pulls apart to disconnect all poles from the circuit.		3-pole terminal block. Pulls apart to disconnect all poles from the circuit.	
Specifications				
Certifications (See page 12-3)	600V AC/DC		600V AC/DC	
Voltage Rating	25 A		60 A	
Maximum Current (per pole)	#20...12 AWG (0.75...4 mm ²)		#14...4 AWG (2.5...25 mm ²)	
Wire Range (Rated Cross Section)*	0.38 in. (9.7 mm)		0.38 in. (9.7 mm)	
Wire Strip Length	6...16 lb•in (0.7...1.8 N•m)		10...30 lb•in (1.1...3.4 N•m)	
Recommended Tightening Torque	-40...+22 °F (-40...+105 °C)		-40...+221 °F (-40...+105 °C)	
Insulation Temperature Range	Terminal Blocks		Terminal Blocks	
	Cat. No.	Pkg Qty.	Cat. No.	Pkg Qty.
Terminal Block	1492-EC85	1	1492-ED103	1
	Accessories (page 12-109)	Accessories (page 12-109)	Accessories (page 12-109)	Accessories (page 12-109)
	Cat. No.	Pkg Qty.	Cat. No.	Pkg Qty.
Jumpers: 2-Pole Uninsulated	1492-N38	50	1492-N38	50
Anchor Unit: (required every 12th block)	Not Required	—	Not Required	—
End Piece	Not Required	—	Not Required	—

* #8-32 screw.

* Both terminal blocks accept 1 wire per terminal.